

breglobal

**Test report for a KEI
Industries Limited
4x70mm² LSZH FR cable
to BS 6387:1994
Clause 11**


Prepared for:
KEI Industries Ltd.
SP-919, 920, 922 RIICO
Industrial Area
Bhiwadi
Alwar
India

24 April 2013

Test report number 285277



0578



Prepared on behalf of BRE Global by

Name Ewan MacDonald

Position Consultant

Signature 

Approved on behalf of BRE Global by

Name Dave Hoare

Position Senior Consultant

Date 24 April 2013

Signature 

BRE Global
Bucknalls Lane
Watford
Herts
WD25 9XX
T + 44 (0) 1923 664100
F + 44 (0) 1923 664994
E enquiries@breglobal.com
www.breglobal.com


BRE Global is not UKAS accredited to make opinions and interpretation. Any opinions and interpretations included as part of this report are clearly marked as such.



0578

This report may only be distributed in its entirety and in accordance with the terms and conditions of the contract. Test results relate only to the items tested. We have no responsibility for the design, materials, workmanship or performance of the product or items tested. This report does not constitute an approval, certification or endorsement of the product tested.


This report is made on behalf of BRE Global. By receiving the report and action on it, the client accepts that no individual is personally liable in contract, tort or breach of statutory duty (including negligence). No third party has any right to rely on this report.



1 Introduction

The requirement of the work was to determine the performance of a cable when it is subjected to BS 6387:1994 Clause 11 - Resistance to fire characteristics [1].

The client for this work was, KEI Industries Limited, Bhiwadi, Alwar, India. The client's work request is given in BRE Global Quotation 285277 dated 18 February 2013.



2 Details of sample received and tests carried out

The sample tested was a 43.7mm diameter, 4 core cable comprising 4 off 70mm² insulated, stranded copper conductor with mica glass tape, filler rods, glass binder tape, bedding, steel wire armour and a black over sheath. The over sheath had the following printed marking;

'KEI 4Cx70 SQMM 600/1000V LSZH FR CABLE IEC 60502-1 BS 6387 CAT : CWZ 2013'

The test specimen was supplied by the client and received on 26 February 2013. BRE Global was not involved in the sample selection process and therefore cannot comment upon the relationship between samples supplied for test and the product supplied to market.

The client requested that the following clauses of BS 6387:1994 were undertaken:


Clause 11.1 - Fire alone (Category C)

Clause 11.2 - Fire with water (Category W)

Clause 11.3 - Fire with mechanical shock (Category Z)

and this report should be read in conjunction with it.

The tests were conducted between 13 March 2013 and 26 March 2013. Prior to the tests being carried out, the sample was conditioned as required by the test standard.



3 Test results

3.1 BS 6387:1994 Clause 11.1 Annex D.1 & D.2 - Resistance to fire alone


Cable type	Test category	Burner Temp (°C)	Test duration	Test Voltage	Comment	Result
4x70mm ²	C	962	180min	600/1000V	No fuses ruptured or lamps extinguished	Pass

3.2 BS 6387:1994 Clause 11.2 Annex D.1 & D.3 - Resistance to fire with water

Cable type	Test category	Burner Temp (°C)	Test duration	Test Voltage	Comment	Result
4x70mm ²	W	670	30min	600/1000V	No fuses ruptured or lamps extinguished	Pass

3.3 BS 6387:1994 Clause 11.3 Annex D.1 & D.4 - Resistance to fire with mechanical shock

Cable type	Test category	Burner Temp (°C)	Test duration	Test Voltage	Comment	Result
4x70mm ²	Z	961	15min	600/1000V	No fuses ruptured or lamps extinguished	Pass



4 Conclusion

The BS 6387:1994 Clauses 11.1 to 11.3 has the following acceptance criteria:

'When a cable sample is tested:

no fuse shall be ruptured,

nor any lamp extinguished during the period of the test'.

The KEI Industries Limited 4x70mm² LSZH FR cable described in Section 2 of this report met the requirements of BS 6387:1994 Clause 11.1 (Category C), Clause 11.2 (Category W) and Clause 11.3 (Category Z).

5 Reference

1. BS 6387:1994, 'Performance requirements for cables to maintain circuit integrity under fire conditions', British Standards Institution, London 1994.

=====REPORT ENDS=====